



IFUX7.E180031
Luminaires for Use in Hazardous Locations Certified for Canada

[Page Bottom](#)

Luminaires for Use in Hazardous Locations Certified for Canada

[See General Information for Luminaires for Use in Hazardous Locations Certified for Canada](#)

F H PAPANMEIER GMBH & CO KG
POSTFACH 16 20
58211 SCHWERTE, GERMANY

E180031

Class I, Groups C and D, rated 120 v max, 35 , 50 and 100 watts, may be suitable for use in wet locations, for 35 and 50 watts use supply conductors suitable for at least 90 C, for 100 watts use supply conductors suitable for at least 110 C, Model(s) USL08-EX

[Last Updated](#) on 2015-12-31

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".